



**Lodos activados.**

Computer Assisted Procedure for the Design and Evaluation of  
Wastewater Treatment Systems

CCCC AAAA PPPPP DDDDD EEEEE TTTTTTT PPPPP CCCCC  
CC CC AA AA PP PP DD DD EE TT PP PP CC CC  
CC AA AA PP PP DD DD EE TT PP PP CC  
CC AA AA PPPPP DD DD EEEEE TT ==== PPPPP CC  
CC AAAAAA PP DD DD EE TT PP CC  
CC CC AA AA PP DD DD EE TT PP CC CC  
CCCC AA AA PP DDDDD EEEEE TT PP CCCCC

Version 2.06

Hydromantis, Inc. Copyright(c) 1985,1986 Jan. 1989  
S/N: HM01.0203.0206

Single-User License Issued to:

\*\*\*\*\*  
\* Comision Nacional del Agua \*  
\* Gerencia de Tratamiento de Agua\*  
\* Cda. de J. Sanchez Azcona #1723\*  
\* Mexico, D.F. 03100 \*  
\* 524-3795 \*  
\*\*\*\*\*

Input data file: UTLA1.TXT

SMALL FACILITIES

IS NOT A VALID PROCESS CARD

LIQUID LINE

BLOCK PRELIM

BLOCK PRIMAR

BLOCK ACTIVA

BLOCK FILTRA

BLOCK CHLORI

HLOR NOT A VALID PROCESS - ON BLOCK CARD

SECONDARY SLUDGE LINE

BLOCK BMIX

IX NOT A VALID PROCESS - ON BLOCK CARD

PRIMARY SLUDGE LINE

BLOCK AEROBI

BI NOT A VALID PROCESS - ON BLOCK CARD

BLOCK DRYING

NG NOT A VALID PROCESS - ON BLOCK CARD

WASTEWATER CHARACTERISTICS

AVERAGE FLOW 0.1386 MGD INITIAL 0.1386 MGD (GASTO = 6 L/SEG

TEMPERATURE SUMMER 17 WINTER 14 C

SUSPENDED SOLIDS 460 MG/L

VOLATILE SOLIDS 60 %

BOD5 581 MG/L

SBOD 250 MG/L

COD 1100 MG/L



SCOD 500 MG/L  
PH 8.0  
PO4 20 MG/L  
TKN 51 MG/L  
NH3 35 MG/L  
OIL AND GREASE 94 MG/L  
DESIRED EFFLUENT CHARACTERISTICS  
UNIT COSTS (COSTOS COMUNES DE PLANTAS, ESTIMADOS)  
EIGHT INCH PIPE 4.4 DLL/PIE CODO 44 D/U TEE 70.4 DLL/U VALV 770 DLL/UNID  
BUILDING COST 22 DLL/PIE2 = 236.5 DLL/M2  
WALL CONCRETE 22 DLL/YARDA3 = 286 DLL/M3  
SLAB CONCRETE 99 DLL/YARDA3 = 129.8 DLL/M3  
EXCAVATION COST 4.4 DLL/YARDA3 = 5.874 DLL/M3  
ELECTRICITY .0495 DLL/KWHR  
CRANE RENTAL 74 DLL/HR  
LABOR RATE 7.2 DLL/HR  
OPERATOR 5.5 DLL/HR  
INSTALLATION LABOR RATE 7.7 DLL/HR  
LAND COST 4057.5 DLL/ACRE (APROX. 10000 Dlls/HA)  
MARSHALL AND SWIFT INDEX 1200 ESTIMADOS A SEPT. 1998  
LARGE CITY EPA INDEX 320  
ENGINEERING NEWS RECORD INDEX 6580.7  
PIPE COST INDEX 595

END

CONTROL CARDS

ANALYSE

OUTPUT QUANTITIES

LIST TOTAL OF 10 TRAINS

GO I=10.00 NYD=20.00 NYC=1.5

1 COST ANALYSIS INPUT PARAMETERS

Interest rate 10.000 %  
Planning period 20 years

0 UNIT PRICES AND COSTS INDICES

I Building 22.00 \$/sq ft  
I Excavation 4.40 \$/cu yd  
I Wall concrete 22.00 \$/cu yd  
I Slab concrete 99.00 \$/cu yd  
I Marshall and Swift index 1200.00  
I Crane rental 74.00 \$/hr  
I EPA construction cost index 320.00  
D Canopy roof 15.75 \$/sq ft  
I Labor rate 7.20 \$/hr  
I Operator class II 5.50 \$/hr  
I Electricity 0.05 \$/kWhr  
D Chemical costs  
Lime 0.03 \$/lb  
Alum 0.04 \$/lb  
Iron salts 0.06 \$/lb  
Polymer 1.62 \$/lb  
I Engineering News Record cost index 6580.70  
D Handrail 25.20 \$/ft  
I Pipe cost index 595.00  
I Pipe installation labor rate 0.00 \$/hr  
I Eight inch pipe 4.40 \$/ft  
I Eight inch pipe bend 44.00 \$/unit  
I Eight inch pipe tee 70.40 \$/unit



1 Eight inch pipe valve 770.00 \$/unit  
 1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

=====

0 ANALYZE 1 TRAIN No 1  
 0 INFLUENT

LIQUID CHARACTERISTICS

FLOW (MGD)	SOLIDS (mg/l)	(mg/l)	(mg/l)
Maximum 0.1386	Suspended 460.00	BOD5 581.00	TKN 51.00
Average 0.1386	Volatile 60.00 %	BOD5S 250.00	NH3 35.00
Minimum 0.1386	Settleable 15.00	COD 1100.00	NO2 0.00
		CODS 500.00	NO3 0.00
Temp (W) 14.0 C	Oil & grease 94.00	PO4 20.00	
Temp (S) 17.0 C	Cations 160.00		
pH 8.0	Anions 160.00		

0 SLUDGE CHARACTERISTICS

	Primary	Secondary	Chemical
Volume (gal/d)	0.00	0.00	0.00
% Solids	0.00	0.00	0.00
% Volatile	0.00	0.00	0.00

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

=====

0 ANALYZE 1 TRAIN No 1  
 0-----

0BAR SCREENS

0D Wet weather flow factor	0.350E+01
Wet weather flow	0.485E+00 MGD
D Maximum head loss through screens	0.500E+00 feet
D Bar spacing	0.100E+01 inches
D Width of bars	0.313E+00 inches
D Bar shape factor	0.167E+01
D Slope of bars	0.100E+02 degrees
Width of channel	0.200E+01 feet
Depth of channel	0.216E+01 feet

0-----

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

=====

0 ANALYZE 1 TRAIN No 1  
 0QUANTITIES FOR BAR SCREENS

0 Length of channel	0.140E+02 feet
Volume of earthwork	0.342E+03 cu ft
Volume of wall concrete	0.658E+02 cu ft
Volume of slab concrete	0.543E+02 cu ft
Operation manpower	0.317E+01 pers-hrs/yr
Maintenance manpower	0.801E+01 pers-hrs/yr
Energy requirement	0.727E+03 kWhr/yr
O & M material and supply cost	0.200E+01 %

LIQUID CHARACTERISTICS

FLOW (MGD)	SOLIDS (mg/l)	(mg/l)	(mg/l)
Maximum 0.1386	Suspended 460.00	BOD5 581.00	TKN 51.00
Average 0.1386	Volatile 60.00 %	BOD5S 250.00	NH3 35.00
Minimum 0.1386	Settleable 15.00	COD 1100.00	NO2 0.00



CODS 500.00 NO3 0.00  
 Temp (W) 14.0 C Oil & grease 94.00 PO4 20.00  
 Temp (S) 17.0 C Cations 160.00  
 pH 8.0 Anions 160.00

0 SLUDGE CHARACTERISTICS  
 Primary Secondary Chemical  
 Volume (gal/d) 0.00 0.00 0.00  
 % Solids 0.00 0.00 0.00  
 % Volatile 0.00 0.00 0.00

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

0 ANALYZE 1 TRAIN No 1

0 PRIMARY CLARIFIER

0 Circular Clarifier

0D Surface overflow rate 0.100E+04 gal/day-sqft  
 Surface area 0.139E+03 sq ft  
 D Side water depth 0.900E+01 feet  
 Detention time 0.162E+01 hours  
 Solid loading 0.384E+01 lb/sqft-day  
 D Weir loading 0.150E+05 gal/day-ft  
 Weir length 0.924E+01 feet  
 Volume of sludge produced 0.880E+03 gal/day  
 D Suspended solids removal 0.580E+02 %  
 D BOD removal 0.320E+02 %  
 D COD removal 0.400E+02 %  
 D TKN removal 0.500E+01 %  
 D PO4 removal 0.500E+01 %

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

0 ANALYZE 1 TRAIN No 1

0QUANTITIES FOR SEDIMENTATION

0CIRCULAR CLARIFIER

0PRIMARY CLARIFIER

Excess capacity factor 0.100E+01  
 Calculated surface area 0.139E+03 sq ft  
 Adjusted surface area 0.139E+03 sq ft  
 Average daily wastewater flow 0.139E+00 MGD  
 Number of circular clarifiers 2  
 Number of batteries 1  
 Surface area per unit 0.693E+02 sq ft  
 Diameter of unit 0.100E+02 feet  
 Earthwork required 0.378E+04 cu ft  
 Sidewater depth 0.900E+01 feet  
 Thickness of the slab 0.101E+02 inches  
 Wall thickness 0.115E+02 inches  
 Total wall concrete required 0.851E+03 cu ft  
 Total slab concrete required 0.274E+03 cu ft  
 Maintenance manpower required 0.200E+03 pers-hours/yr  
 Operation manpower required 0.350E+03 pers-hours/yr  
 Electrical energy required 0.750E+04 kWhr/yr

LIQUID CHARACTERISTICS



FLOW (MGD)	SOLIDS (mg/l)	(mg/l)	(mg/l)
Maximum 0.1386	Suspended 193.20	BOD5 395.08	TKN 48.45
Average 0.1386	Volatile 60.00 %	BOD5S 250.00	NH3 35.00
Minimum 0.1386	Settleable 0.00	COD 660.00	NO2 0.00
		CODS 500.00	NO3 0.00
Temp (W) 14.0 C	Oil & grease 94.00	PO4 19.00	
Temp (S) 17.0 C	Cations 160.00		
pH 8.0	Anions 160.00		

0 SLUDGE CHARACTERISTICS

	Primary	Secondary	Chemical
Volume (gal/d)	880.44	0.00	0.00
% Solids	4.00	0.00	0.00
% Volatile	60.00	0.00	0.00

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

0 ANALYZE 1 TRAIN No 1

0ACTIVATED SLUDGE

0D Hydraulic detention time	0.300E+02 hours
D Solids detention time	0.250E+02 days
D Underflow concentration	0.100E+05 mg/l
Volume of aeration tank	0.173E+00 MG
Mixed liquor suspended solids	0.351E+04 mg/l
Food to microorganism ratio	0.901E-01
Sludge production	0.203E+03 lbs/day
Sludge recycle ratio	0.341E-04

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

0 ANALYZE 1 TRAIN No 1

0QUANTITIES FOR ACTIVATED SLUDGE

0 Diameter of package plant	0.480E+02 feet
Volume of reinforced slab concrete	0.153E+04 cu ft
Operation manpower required	0.126E+04 pers-hrs/yr
Maintenance manpower required	0.695E+03 pers-hrs/yr
Energy required	0.104E+05 kWhr/yr
O & M material and supply costs	0.285E+01 %

LIQUID CHARACTERISTICS

FLOW (MGD)	SOLIDS (mg/l)	(mg/l)	(mg/l)
Maximum 0.1386	Suspended 30.00	BOD5 3.55	TKN 10.00
Average 0.1386	Volatile 60.00 %	BOD5S 0.99	NH3 10.00
Minimum 0.1386	Settleable 0.00	COD 5.32	NO2 0.00
		CODS 1.48	NO3 0.00
Temp (W) 14.0 C	Oil & grease 0.00	PO4 15.00	
Temp (S) 17.0 C	Cations 160.00		
pH 8.0	Anions 160.00		

0 SLUDGE CHARACTERISTICS

	Primary	Secondary	Chemical
Volume (gal/d)	880.44	2360.37	0.00
% Solids	4.00	1.00	0.00
% Volatile	60.00	60.00	0.00

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico



0 ANALYZE 1 TRAIN No 1

0-----

0PACKAGE PLANT GRAVITY FILTRATION

0I Hydraulic loading rate 0.500E+01 gpm/sq ft  
 I Number of filter cells 4  
 D Minimum backwash rate 0.200E+02 gpm/sq ft  
 D Minimum backwash period 0.100E+02 min  
 I Number of backwash volumes 2  
 Filter area required (hydraulic loading) 0.192E+02 sq ft  
 Filter area required (peak flow) 0.257E+02 sq ft  
 Design filter surface area 0.257E+02 sq ft  
 Volume of backwash surge tank 0.343E+03 cu ft

0-----

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

=====

0 ANALYZE 1 TRAIN No 1

0QUANTITIES FOR GRAVITY FILTRATION

0 Volume of reinforced slab concrete 0.696E+02 cu ft  
 Volume of reinforced wall concrete 0.445E+03 cu ft  
 Width of backwash surge tank 0.495E+01 feet  
 Length of backwash surge tank 0.990E+01 feet  
 Volume of earthwork required 0.529E+04 cu ft  
 Electrical energy required 0.120E+04 kWhr/year  
 Maintenance manpower required 0.136E+03 pers-hours/year  
 Operation manpower required 0.208E+03 pers-hours/year  
 O & M material and supply costs 0.500E+01 %

LIQUID CHARACTERISTICS

FLOW (MGD)	SOLIDS (mg/l)	(mg/l)	(mg/l)	(mg/l)
Maximum 0.1386	Suspended 12.00	BOD5 0.99	TKN 10.00	
Average 0.1386	Volatile 60.00 %	BOD5S 0.99	NH3 10.00	
Minimum 0.1386	Settleable 0.00	COD 1.48	NO2 0.00	
		CODS 1.48	NO3 0.00	
Temp (W) 14.0 C	Oil & grease 0.00	PO4 15.00		
Temp (S) 17.0 C	Cations 160.00			
pH 8.0	Anions 160.00			

0 SLUDGE CHARACTERISTICS

	Primary	Secondary	Chemical
Volume (gal/d)	880.44	2360.37	0.00
% Solids	4.00	1.00	0.00
% Volatile	60.00	60.00	0.00

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

=====

0 ANALYZE 1 TRAIN No 1

0-----

0LIQUID PREL 0 PRIM 0 ACTI 0 FILT 0

0-----

0 ===> COST SUMMARY <===

	OPER		MAINT		TOTAL				
UNIT	CAPITAL COST	AMMORT COST	LABOR COST	LABOR COST	POWER COST	MATERIAL COST	CHEMICAL COST	O & M COST	
	\$	\$/yr	\$/yr	\$/yr	\$/yr	\$/yr	\$/yr	\$/yr	
SCREENS	33994	3989	16	30	35	679	0	760	
PRIM CLA	79673	8662	1867	770	371	796	0	3804	



ACT SLUD 161568 18923 6716 2675 514 3988 0 13893  
 FILTRATI 295524 34696 1108 523 59 11746 0 13436  
 0SUB TOTAL 570761 66272 9708 4000 981 17211 0 31893

0DIRECT COSTS

Control and instrument 7 \$  
 Profit/overhead 125568 \$

0 SUB TOTAL (OTHER DIRECT) 125575 \$ TOTAL CONSTRUCTION COST 696336 \$

0INDIRECT COSTS

Misc non const costs 34816 \$  
 Admin/legal 13926 \$  
 201 planning 24371 \$  
 A/E design fee 55051 \$  
 Inspection 13926 \$  
 Contingencies 55706 \$  
 Technical costs 13926 \$

0 SUB TOTAL (INDIRECT) 211722 \$

0LAND COSTS 36517 \$ 9. acres

INTEREST DURING CONSTRUCTION 70843 \$

0ADMINISTRATIVE COST 2142 \$/yr

LABORATORY COST 10987 \$/yr

0TOTAL PROJECT COST 1015418 \$ TOTAL CONSTRUCTION COST 696336 \$

FINAL YEAR O & M 45033 \$/yr TOTAL STEP III COST 935996 \$

INITIAL YEAR O & M 45033 \$/yr PRESENT WORTH (APP. A) 1417537 \$

1Comision Nacional del Agua, Gerencia de Tratamiento de Agua, Mexico

0 ANALYZE 1 TRAIN No 1

0USER CHARGE SUMMARY

D EPA grant 0.750E+02 %  
 D State grant 0.000E+00 %  
 D Allowance for financing 0.300E+01 %  
 Bonds Percent Rate Life  
 D Revenue 100.00 10.00 30  
 D General obligation 0.00 0.00 30  
 D Other 0.00 0.00 30  
 D Number of billing units 0.506E+05 \$/T gal  
 D Existing sewer rate 0.000E+00  
 D Persons per household 0.350E+01  
 D Gallons/capita/day (water use) 0.100E+03 gal/cap-day  
 D Current annual O & M cost 0.000E+00 \$/year  
 Total project cost 0.102E+07 \$  
 EPA Eligible cost 0.979E+06 \$  
 Local share 0.289E+06 \$  
 Annual debt service 0.306E+05 \$/year  
 Principal and interest reserve 0.437E+04 \$/year  
 Contingency reserve 0.437E+04 \$/year  
 Total annual operating cost 0.844E+05 \$/year  
 Treatment cost  
 Cost per 1000 gallons treated (new system) 0.167E+01 \$/T gal  
 Cost per 1000 gallons treated (total system) 0.167E+01 \$/T gal  
 Cost per billing unit (new system) 0.167E+01 \$/T gal  
 Cost per billing unit (total system) 0.167E+01 \$/T gal  
 Cost per household (new system) 0.175E+02 \$/month  
 Cost per household (total system) 0.175E+02 \$/month

0-----  
 1



0	Present TRN	Project TRN	Construct TRN	O&M	TRN	Energy TRN				
	Worth #	Cost #	Cost #	Cost #	Cost #					
	1417537	1	1015418	1	696336	1	45033	1	981	1
0TRAIN N 1										
LIQUID PREL 0 PRIM 0 ACTI 0 FILT 0										